

# GARR HOME INSPECTIONS



## Radon Test Report

May 03, 2020  
Batch #: 050320-2

**Customer:**

MARK GARR

**Test Site:**

 7207 SHEFFORD LANE  
LOUISVILLE KY 40242

E-PERM® Electret Ion Chambers were used for short-term radon screening measurements that were conducted at the above referenced test site by: GARR HOME INSPECTIONS

**The Results are as follows:**

Serial No.	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SLE123	SST	Basement	01-May-2020	10:00 AM	03-May-2020	2:00 AM	30.2
SLE456	SST	Basement	01-May-2020	10:00 AM	03-May-2020	2:00 AM	29.9

**Average Radon Concentration in: Basement 30.1 pCi/L**

**Deployed By:** MARK GARR

**Retrieved By:** MARK GARR

**Analyzed By:** MARK GARR

**Conditions:** Requirements for Closed-Building Met

**Tampering:**
**Weather:** No Abnormal Weather Conditions

**Active Mitigation:** No

**Comment:**

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (USEPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the USEPA web site at [www.USEPA.gov/radon](http://www.USEPA.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Authentisign  
*Mark Garr*



5/3/2020 10:04:03 PM EDT

05/03/2020

**Signature:**
**Date:**